



Zhejiang Jinyuan Copper Mfg. Co., Ltd

Zhongshang Industrial Zone, Yuhuan

Zhejiang, China 317605

Tel:0086-576-87416999

Fax:0086-576-87416666

E-mail:sales@jinyuanbrass.com

www.jinyuanbrass.com



ISO 9001:2008



金源实验室 JINYUAN Laboratory

静水爆破测试报告 Hydrostatic Sustained Pressure Test ASSE 1061-2011		报告编号 Report No.	检验日期 Checking Date.
客户 Client :		订单号 Order No.:	
型号 Part No. : PUSH FIT FITTINGS			
产品 Product : 3/4" Tee		测试时间 Testing time: 2 hours	
管材 Tube : PEX			
介质 Testing medium: Water			
测试条件 TESTING CONDITION			
Condition 1:		Condition 1:	
Testing Qty: 4pcs of 3/4" Tee		Testing Qty: 4pcs of 3/4" Tee	
Testing Pressure: 3.5 Mpa		Testing Pressure: 1.5 Mpa	
Water temperature: 24°C		Water temperature: 85°C	
测试结果 TESTING RESULT			
* No leakage * No damage of fittings components * No Tube slip out			
测试照片 TESTING PICTURES			
			
产品处置 PART DISPOSITION			
☒ Accepted 接受 ☐ Conditional Approval 让步接受 ☐ Rejected 拒收			
JINYUAN SIGNATURE: CHEN		TITLE: QC Engineer	DATE: 2014.6.10

